



SECURITY SYSTEM RFP

EL RIO NW EXPANSION Q AND A

Q1: Retention Requirements: We guarantee a minimum of 30 days of continuous 24/7 recording. Does the RFP specify any additional retention requirements or preferences for the security cameras?

A1: No, there are no additional requirements.

Q2: Resolution Standards: Our cameras range from 3MP to 4K resolution, ensuring high-quality video coverage. Could you confirm if there is a minimum resolution requirement or any specific resolution preferences for the cameras outlined in the RFP?

A2: Minimum resolution is 5k.

Q3: Infrastructure Compatibility: Our hybrid cloud-based system eliminates the need for bulky on-premise servers, optimizes bandwidth usage, and allows for secure remote access. Each camera operates with PoE (Power over Ethernet). Does your current network infrastructure support PoE, or would additional infrastructure upgrades be required?

A3: It will depend on system selection and working with IT.

Q4: Please confirm that the security company will wire, provide, and install all electric strikes (both cut-in and rim mounted) on doors with readers. The door company will provide all

exit devices and electric latch retraction for these devices on all applicable doors with readers.

A4: Cabling company will do wiring to the IDF and IT will patch the cable into the Network switch and provide an IP address to the Security company. The door company will provide electric strikes. We will share the door schedule and hardware groups so that you can see what's being provided and all other items required to make the system work should be provided by the Security company.